

## CERTIFICATE OF ANALYSIS

**Work Order** : **ES2019489**  
**Client** : **INTEGRA WATER TREATMENT SOLUTIONS**  
**Contact** : **SAMPLE RESULTS**  
**Address** : **UNIT B 195 Port Hacking Rd.**  
**MIRANDA NSW, AUSTRALIA 2228**  
**Telephone** : **+61 9574 0000**  
**Project** : **Alexander Downs Wholesale Meats**  
**Order number** : **----**  
**C-O-C number** : **----**  
**Sampler** : **Jeff Moulds (integra)**  
**Site** : **AD/ Kurri Meats**  
**Quote number** : **EN/222 NSW Batches only**  
**No. of samples received** : **4**  
**No. of samples analysed** : **4**

**Page** : 1 of 4  
**Laboratory** : Environmental Division Sydney  
**Contact** : Wael Saleh  
**Address** : 277-289 Woodpark Road Smithfield NSW Australia 2164  
**Telephone** : +61 2 8784 8555  
**Date Samples Received** : 04-Jun-2020 16:10  
**Date Analysis Commenced** : 04-Jun-2020  
**Issue Date** : 12-Jun-2020 14:31



Accreditation No. 825  
 Accredited for compliance with  
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

**Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.**

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Gregory Towers	Technical Officer	Chemistry, Newcastle West, NSW
Ivan Taylor	Analyst	Sydney Inorganics, Smithfield, NSW



## General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.  
LOR = Limit of reporting  
^ = This result is computed from individual analyte detections at or above the level of reporting  
ø = ALS is not NATA accredited for these tests.  
~ = Indicates an estimated value.

- Sodium Adsorption Ratio (where reported): Where results for Na, Ca or Mg are <LOR, a concentration at half the reported LOR is incorporated into the SAR calculation. This represents a conservative approach for Na relative to the assumption that <LOR = zero concentration and a conservative approach for Ca & Mg relative to the assumption that <LOR is equivalent to the LOR concentration.



## Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	wastewater treatment plant in	wastewater treatment plant out	Pond number 2	Pond number 3	----
Client sampling date / time				04-Jun-2020 08:00	04-Jun-2020 00:00	04-Jun-2020 00:00	04-Jun-2020 00:00	----	
Compound	CAS Number	LOR	Unit	ES2019489-001	ES2019489-002	ES2019489-003	ES2019489-004	-----	
				Result	Result	Result	Result	----	
<b>EA005: pH</b>									
pH Value	----	0.01	pH Unit	7.00	7.28	7.44	7.66	----	
<b>EA006: Sodium Adsorption Ratio (SAR)</b>									
^ Sodium Adsorption Ratio	----	0.01	-	----	----	----	9.72	----	
<b>EA010P: Conductivity by PC Titrator</b>									
Electrical Conductivity @ 25°C	----	1	µS/cm	1810	1630	1600	1530	----	
<b>EA015: Total Dissolved Solids dried at 180 ± 5 °C</b>									
Total Dissolved Solids @180°C	----	10	mg/L	----	----	----	773	----	
<b>EA025: Total Suspended Solids dried at 104 ± 2°C</b>									
Suspended Solids (SS)	----	5	mg/L	2890	877	182	144	----	
<b>ED093F: Dissolved Major Cations</b>									
Calcium	7440-70-2	1	mg/L	----	----	----	16	----	
Magnesium	7439-95-4	1	mg/L	----	----	----	9	----	
Sodium	7440-23-5	1	mg/L	----	----	----	196	----	
<b>EK055G: Ammonia as N by Discrete Analyser</b>									
Ammonia as N	7664-41-7	0.01	mg/L	----	----	----	42.3	----	
<b>EK057G: Nitrite as N by Discrete Analyser</b>									
Nitrite as N	14797-65-0	0.01	mg/L	----	----	----	0.50	----	
<b>EK058G: Nitrate as N by Discrete Analyser</b>									
Nitrate as N	14797-55-8	0.01	mg/L	----	----	----	0.58	----	
<b>EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser</b>									
Nitrite + Nitrate as N	----	0.01	mg/L	----	----	----	1.08	----	
<b>EK061G: Total Kjeldahl Nitrogen By Discrete Analyser</b>									
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	----	----	----	50.0	----	
<b>EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser</b>									
^ Total Nitrogen as N	----	0.1	mg/L	----	----	----	51.1	----	
<b>EK067G: Total Phosphorus as P by Discrete Analyser</b>									
Total Phosphorus as P	----	0.01	mg/L	----	----	----	3.87	----	
<b>EP020: Oil and Grease (O&amp;G)</b>									
Oil & Grease	----	5	mg/L	----	----	----	6	----	
<b>EP030: Biochemical Oxygen Demand (BOD)</b>									
Biochemical Oxygen Demand	----	2	mg/L	----	----	----	163	----	
<b>EP030: Carbonaceous Biochemical Oxygen Demand (CBOD)</b>									
CBOD	----	2	mg/L	----	----	----	104	----	



### Analytical Results

Sub-Matrix: <b>WATER</b> (Matrix: <b>WATER</b> )				Client sample ID	wastewater treatment plant in	wastewater treatment plant out	Pond number 2	Pond number 3	----
Client sampling date / time					04-Jun-2020 08:00	04-Jun-2020 00:00	04-Jun-2020 00:00	04-Jun-2020 00:00	----
Compound	CAS Number	LOR	Unit	ES2019489-001	ES2019489-002	ES2019489-003	ES2019489-004	-----	
				Result	Result	Result	Result	----	

**EP030: Carbonaceous Biochemical Oxygen Demand (CBOD) - Continued**