

CERTIFICATE OF ANALYSIS

Work Order : **ES2208338**
Client : **INTEGRA WATER TREATMENT SOLUTIONS**
Contact : **SAMPLE RESULTS**
Address : **UNIT B 195 PORT HACKING ROAD**
MIRANDA NSW, AUSTRALIA 2228
Telephone : **+61 9574 0000**
Project : **Alexander Downs Wholesale Meats**
Order number : **----**
C-O-C number : **----**
Sampler : **MICHAEL AXE**
Site : **AD/Kurri Meats**
Quote number : **SYBQ/406/21**
No. of samples received : **4**
No. of samples analysed : **4**

Page : 1 of 3
Laboratory : Environmental Division Sydney
Contact : Wael Saleh
Address : 277-289 Woodpark Road Smithfield NSW Australia 2164
Telephone : +61 2 8784 8555
Date Samples Received : 09-Mar-2022 19:00
Date Analysis Commenced : 10-Mar-2022
Issue Date : 17-Mar-2022 18:16



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Senior Chemist - Inorganics	Sydney Inorganics, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- TDS by method EA-015 may bias high for sample 1 due to the presence of fine particulate matter, which may pass through the prescribed GF/C paper.
- Sodium Adsorption Ratio (where reported): Where results for Na, Ca or Mg are <LOR, a concentration at half the reported LOR is incorporated into the SAR calculation. This represents a conservative approach for Na relative to the assumption that <LOR = zero concentration and a conservative approach for Ca & Mg relative to the assumption that <LOR is equivalent to the LOR concentration.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Sample ID		Waste Water Plant In	Waste Water Plant Out	Pond Number 2	Pond Number 3	----
Sampling date / time		09-Mar-2022 00:00		09-Mar-2022 00:00	09-Mar-2022 00:00	09-Mar-2022 00:00	09-Mar-2022 00:00	----
Compound	CAS Number	LOR	Unit	ES2208338-001	ES2208338-002	ES2208338-003	ES2208338-004	-----
				Result	Result	Result	Result	----
EA005P: pH by PC Titrator								
pH Value	----	0.01	pH Unit	7.04	7.55	7.69	7.65	----
EA010P: Conductivity by PC Titrator								
Electrical Conductivity @ 25°C	----	1	µS/cm	1080	1020	873	901	----
EA015: Total Dissolved Solids dried at 180 ± 5 °C								
Total Dissolved Solids @180°C	----	10	mg/L	821	704	520	529	----
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)	----	5	mg/L	557	228	210	617	----
ED093F: Dissolved Major Cations								
Calcium	7440-70-2	1	mg/L	----	----	----	14	----
Magnesium	7439-95-4	1	mg/L	----	----	----	6	----
Sodium	7440-23-5	1	mg/L	----	----	----	102	----
ED093F: SAR and Hardness Calculations								
[^] Sodium Adsorption Ratio	----	0.01	-	6.42	8.14	6.24	5.74	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	----	----	----	27.2	----
EK057G: Nitrite as N by Discrete Analyser								
Nitrite as N	14797-65-0	0.01	mg/L	----	----	----	0.48	----
EK058G: Nitrate as N by Discrete Analyser								
Nitrate as N	14797-55-8	0.01	mg/L	----	----	----	1.67	----
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Nitrite + Nitrate as N	----	0.01	mg/L	----	----	----	2.15	----
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	----	----	----	60.8	----
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser								
[^] Total Nitrogen as N	----	0.1	mg/L	----	----	----	63.0	----
EK067G: Total Phosphorus as P by Discrete Analyser								
Total Phosphorus as P	----	0.01	mg/L	----	----	----	25.2	----
EP020: Oil and Grease (O&G)								
Oil & Grease	----	5	mg/L	----	----	----	9	----